

District Civil Hospital Rohtak  
Water Sample Report

No./DCH/RTK/2023/ 370

Date: 9-6-2023

To:

The CMO  
Rohtak

Subject: Testing water sample for Bacteriological.

Reference of your letter no. ADP/2023/253 date 7.5.23

on the subject cited above, the water sample report is as under

Sr.no

Name of Place

Report

1.

The Shri Ram Universal  
School Bhalaut (Rohtak)

The probable coliform count is 250 per 100 ml of water hence the water sample is not fit for human consumption.

Cps

CMO

09/06/23

8  
9.6.23